# ift-Nachweis

## Classification Report



| | |
|---|---|
| **Number** | 20-002493-PR03 (NW-A01-02-en-01) |
| **Owner** | Europa Profil Aluminio S.A.<br>56th Klm National Highway<br>Athens - Lamia<br>32011 Innofita Viotas<br>Greece |
| **Product** | Double tilt and turn casement door with central opening meeting stile |
| Designation | System: **EUROPA EOS 68**<br>Shipping name: **EUROPA EOS 68 DOUBLE SASH** |
| Details | Manufacturer **Europa Profil Aluminio S.A., - Innofita Viotas**; Material **Aluminium system with thermal break**; Type of opening **Turn / tilt and turn**; Opening direction **Active casement DIN right (opening) to the inside, Inactive casement DIN left (opening) to the inside**; Overall dimensions (W x H) **1600 mm x 2200 mm** |
| Special features | Test sequence. The strength, durability and material compatibility of the adhesive system was not part of the test and is tested separately. |

### Result

Air permeability according to EN 12207:2016-12

**Class: 4**

Resistance to wind load according to EN 12210:2016-03

**Class: C4/B4**

Watertightness according to EN 12208:1999-11

**Class: 9A**

**ift** Rosenheim
22.07.2020

Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing

Dimitrios Moustakidis, MSc, Dipl.-Ing.
Operating Testing Officer
Building Component Testing