

# Evidence of Performance

Air permeability, Watertightness, Resistance to wind load, Operating forces



## Test Report

No. 16-003349-PR02

(PB-A01-02-en-01)

Client	Salamander Industrie-Produkte GmbH Jakob-Sigle-Str. 58 86842 Türkheim Germany
Product	Sliding door scheme D
Designation	System designation: evolutionDrive: SF
Performance-relevant product details	Material: PVC-U white
Overall dimensions (WxH)	3,403 mm x 2,488 mm
Special features	Construction with visible internal water flow

### Basis

EN 14351-1:2006+A1:2010

Test standard/s:

EN 1026:2016-03

EN 1027:2016-03

EN 12046-1:2003-11

EN 12211:2016-03

Equivalent national versions (e.g. DIN EN)

Test report 16-003349-PR02

(PB-A01-02-de-01) dated

16.11.2016

### Representation



### Instructions for use

The manufacturer is allowed to use the results obtained for preparing a Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EC. Observe the specifications set out by the applicable product standard.

### Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented, in particular the effects of weathering and ageing were not taken into account.

### Notes on publication

The ift-Guidance Sheet „Advertising with ift test documents“ applies. The cover sheet can be used as an abstract.

The report contains a total of 25 pages.

### Results

Air permeability according to EN 12207:1999-11



**Class 3**

Watertightness according to EN 12208:1999-11



**Class 7A**

Resistance to wind load according to EN 12210:2016-03



**Class C2 / B3**

Operating forces according to EN 13115:2001-07



**Class 1**

ift Rosenheim

15.02.2017

Thomas Stefan, Dipl.-Ing. (FH)  
Head of Testing Department  
Construction Product Testing

Daniel Gromotka, B.Eng.  
Operating Testing Officer  
Construction Product Testing